


ATTESTATION OF CONFORMITY

Issued to: Shenzhen Huaxing New Energy Technology Co., Ltd.
201, NO. 18, Mingcheng Road, Shijing Community, Shijing Street, Pingshan District,
Shenzhen, China

For the product: Battery Energy Storage System

Trade name:  **BATTLINK**

Type/Model: HX-64V314AH-A, BATT-CI-100/241, BATT-CI-100/241-P, BATT-CI-100/241-T

Ratings: See annex

Manufactured by: Shenzhen Huaxing New Energy Technology Co., Ltd.
201, NO. 18, Mingcheng Road, Shijing Community, Shijing Street, Pingshan District,
Shenzhen, China

Subject: Complete evaluation of electrical system of the appliances

Requirements: EN IEC 61000-6-2:2019
EN IEC 61000-6-4:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test file / test report no 4935386.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic Compatibility Directive (EMC) 2014/30/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

Arnhem, 14 April 2025

Number: 4935386.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou Branch



Miranda Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Annex

Document no. : 4935386.01AOC

Ratings:

AC side:

3L+N+PE: 380Vac/400Vac 50Hz/60Hz, 154A

Battery Cluster:

Voltage Range: 648Vdc – 864Vdc,

Rated current: 157A

DC side (Photovoltaic side):

180Vdc - 900Vdc

End